



# **THE WATER THAT BUILT DUBAI: TEN YEARS OF DESALINATION HISTORY IN JEBEL ALI**

**Emilio Ghiazza**

# From 1999 to 2009

Plant	AWARD	START	END
G	1999	15/03/2000	15/03/2000
K1	1999	15/11/2000	26/02/2001
K2	2000	15/04/2002	25/01/2003
L1	2003	25/05/2005	20/10/2007
L2	2005	31/08/2008	In progress
M	2007		

In the last

**10 years**

with common satisfaction of the Contractor and of the Client

**23 MSF Units in 6 Stations**

have been installed by Fisia Italimpianti in Jebel Ali industrial area



M Station  
(Fisia)

L Station I + II  
(Fisia)

G Station  
(Fisia)

G Station  
(Weir)

K Station I + II  
(Fisia)

E Station  
(Hang Jung)

D Station  
(Ansaldo)

Image © 2009 GeoEye  
Image © 2009 DigitalGlobe  
© 2009 Google

11

# Plants' size & Installed capacity

From: HOW MANY PLANTS ?  
To: HOW MUCH WATER ?


Plant	YEAR	MIGD	MIGD (tot.)
G	2000	7,5	7,5
K1	2001	20	27,5
K2	2002	40	67,5
L1	2005	70	137,5
L2	2008	55	192,5
M	2009	140	332,5

**10**  
years



**1.6** millions m<sup>3</sup>/day of fresh water

# Plants' size & Installed capacity



**An exponential growth**


# Single unit capacity

Plant	YEAR	Nr. Of Units	MIGD/unit
G	2000	1	7,50
K1	2001	2	10,00
K2	2002	3	13,33
L1	2005	5	14,00
L2	2008	4	13,75
M	2009	8	17,50

From  
7,5 MIGD  
to  
17,5 MIGD

More than **double** in only 10 years

# Single unit capacity



The single unit size better reflects the **innovation** in the thermal technology field

# Differences and Improvements

The main fields we are going to analyze are:

- Process
- Materials
- Equipment

Which changes and improvements have been carried out across the years?



# Differences and Improvements Process

Plant	m.u.	G	K1	K2	L1	L2	M
Distillate output	m <sup>3</sup> /h	1420,7	1894,2	2525,0	2651,9	2604,5	3314,9
Performance Ratio	kg/2326kJ	8,7	9,0	8,0	8,6	8,4	9,0
Top Brine Temperature	°C	105	105	105	112	112	112
Sea Water Temperature	°C	30	30	30	39	39	37
Brine Recycle Flow	t/h	14100	18900	25300	25900	25300	30500
Cooling Water Flow	t/h	7600	10100	15000	18200	18400	27000
Sea Water Temperature Rise (reject section)	°C	12,0	12,0	12,5	9,5	9,0	8,0
Sea Water Salinity	g/l	46	46	45	45	45	45
Brine Specific Flow	t/h/m	1007	1062	1110	1136	1265	1320
Recovery in-tube velocity	m/s	2,07	2,13	2,10	2,22	2,16	2,09
Reject in-tube velocity	m/s	2,14	2,19	2,02	2,28	2,29	2,33

**The main parameters which are indicative of the overall performances of the distillers**

# Differences and Improvements Materials

TUBE BUNDLES	<ul style="list-style-type: none"><li data-bbox="819 564 1413 628">■ Recovery Section:</li><li data-bbox="819 743 1413 810">■ Reject Section:</li></ul>	CuNi 66/30 instead of CuNi 90/10 in the first stages Titanium instead of CuNi 90/10
EVAPORATOR	<ul style="list-style-type: none"><li data-bbox="819 1002 1440 1066">■ Shell and Internals:</li><li data-bbox="819 1193 1440 1251">■ Deaerator:</li></ul>	Duplex SS instead of Carbon Steel Duplex SS instead of Carbon Steel


# Differences and Improvements

## Tubes Materials

G				L1			
TUBES	Recovery	first stages intermediate stages last stages	CuNi 90/10 CuNi 90/10 Al Br	TUBES	Recovery	first stages intermediate stages last stages	CuNi 66/30 CuNi 90/10 Al Br
	Reject	all stages	CuNi 90/10		Reject	all stages	Titanium
K1				L2			
TUBES	Recovery	first stages intermediate stages last stages	CuNi 90/10 CuNi 90/10 Al Br	TUBES	Recovery	first stages intermediate stages last stages	CuNi 66/30 CuNi 90/10 Al Br
	Reject	all stages	CuNi 90/10		Reject	all stages	Titanium
K2				M			
TUBES	Recovery	first stages intermediate stages last stages	CuNi 90/10 CuNi 90/10 Al Br	TUBES	Recovery	first stages intermediate stages last stages	CuNi 66/30 CuNi 90/10 Al Br
	Reject	all stages	CuNi 90/10		Reject	all stages	Titanium

**Different materials have been used for heat exchange tubes across the last decade.**

# Differences and Improvements Evaporator Materials



**Materials have been used more and more tailored considering corrosion critical areas.**

# Differences and Improvements Equipment

## PUMPS

- Improved materials
- Size doubled in the last 10 years

## VALVES

- Combined isolation / non return valve to reduce electrical consumption
- Control valves automatically actuated for better operability

## CHEMICALS

- Antiscale: pure compound, optimized injection point
- Sodium Sulphite: not provided with no corrosion problems

## DEAERATOR

- Improved materials
- High efficiency even without stripping steam

# Differences and Improvements Equipment

PUMP	G	K1	K2	L1	L2	M
	Flow [m <sup>3</sup> /h]	Flow [m <sup>3</sup> /h]	Flow [m <sup>3</sup> /h]	Flow [m <sup>3</sup> /h]	Flow [m <sup>3</sup> /h]	Flow [m <sup>3</sup> /h]
Main sea water	-	10500	12000	18700	25600	27700
Brine recycle	6800	9100	12200	12500	12200	14800
SW recirculation	2300	2600	6500	5400	5400	7300
Potable water	-	2100	4200	4400	-	4400
Blow-down	3100	3300	4600	4800	4700	5800
Distillate	1520	2100	2560	2670	2610	3320
Condensate	190	260	340	320	340	400

**Pumps size considerably increased along with  
the MSF units capacity growth**

# Differences and Improvements Equipment

Plant	m.u.	G	K1	K2	L1	L2	M
Dosing Rate at 105°C TBT	ppm	2,4	2,4	2,3	2	2	2
Dosing Rate at 112°C TBT	ppm	3	3	2,9	2,5	2,5	2,5
Type	-	solution	solution	solution	pure	pure	pure
Injection Point	-	After BRPs	After BRPs	After BRPs	Before and After BRPs	Before and After BRPs	Before and After BRPs


**the AS dosing system has been optimized in terms of dosing rate, concentration and injection location.**

# A Comparison Between Past and Present

- **First Phase**      **G, K**      **2000 – 2002**
- **Second Phase**   **L**      **2005 – 2008**
- **Third Phase**      **M**      **2009 – 2010**



# First Phase: G,K



# First Phase: G,K


*G: 1 Unit - K I: 2 Units K II: 3 Units*

Plant	m.u.	G	K1	K2
Distillate output	MIGD	7,5	10,0	13,3
Performance Ratio	kg/2326kJ	8,7	9,0	8,0
Top Brine Temperature	°C	105	105	105
SWT	°C	30	30	30
R/D	-	9,6	9,6	9,7
F/R	-	0,54	0,53	0,59
$\Delta T$	°C	12,0	12,0	12,5
tds	g/l	46	46	45
Ws	t/h/m	1007	1062	1110
vi	m/s	2,1	2,1	2,1
vj	m/s	2,1	2,2	2,0

- Increased capacity★
- Low SWT → Low TBT
- High s.w. temperature rise

★ = key factor for this period


# Second Phase: L



# Second Phase: L


*L I: 5 Units - L II: 4 Units*

Plant	m.u.	L1	L2
Distillate output	MIGD	14,0	13,8
Performance Ratio	kg/2326kJ	8,6	8,4
Top Brine Temperature	°C	112	112
SWT	°C	39	39
R / D	-	9,4	9,4
F / R	-	0,70	0,72
$\Delta T$	°C	9,5	9,0
tds	g/l	45	45
Ws	t/h/m	1136	1265
vi	m/s	2,2	2,2
vj	m/s	2,3	2,3

- TBT up to 112 °C   
due to SWT at 39°C
- Lower s.w.  
temperature rise
- Higher reject tubes  
velocity

 = key factor for this period

# Third Phase: M



# Third Phase: M

*M: 8 Units*

Plant	m.u.	M
Distillate output	MIGD	17,5
Performance Ratio	kg/2326kJ	9,0
Top Brine Temperature	°C	112
SWT	°C	37
R / D	-	8,9
F / R	-	0,89
$\Delta T$	°C	8,0
tds	g/l	45
Ws	t/h/m	1320
vi	m/s	2,1
vj	m/s	2,3

- Maximum unit capacity  
(17.5 MIGD)

- Maximum weir chamber load  
(1,320 t/h/m)

- **MSF design limits** 

 = key factor for this period

# Operational Results

Long Term (G,K)

6 - 10 years

Process  
Performances 

PLANT	Guaranteed P.R.	Min P.R.	Max P.R.
G	8,7	9,8	9,9
K1	9,0	9,6	9,7
K2	8,0	8,8	8,9

- Units remain clean after several years of operation

## Mechanical Performances

- Material corrosion in some internal parts of deaerator (C.S. clad or S.S. 316/317 L) and reject section tubes



- use of different material for the Plants of the following phase

# Operational Results

Medium Term (L1) 3 - 5 years

Process  
Performances 

PLANT	Guaranteed P.R.	Min P.R.	Max P.R.
L1	8,6	9,1	9,3

- Optimized thermodynamic design

Mechanical Performances

- Thanks to previous plants experience



- No corrosion problems in deaerator internals and tube bundles



# Operational Results

Short Term (L II)

1 - 2 years

Process  
Performances →

PLANT	Guaranteed P.R.	Min P.R.	Max P.R.
L2	8,4	8,9	9,0

- Satisfactory, to be monitored in the next years

## Mechanical Performances

- Thanks to previous plants experience and accurate material choice



- a trouble-free life of the units and of their associated equipment is expected

# Recent Ideas


The search for MSF technology optimization by Fisia is still going on, focusing in the most recent years on:

- **Materials**
- **Redundancies**
- **Design**

Which improvements are possible for the plants of the next years?

# Recent Ideas

## Choice of materials



evaporator and deaerator main material selection  
applied in Jebel Ali "M"

# Recent Ideas

Avoidance of useless redundancies

Some issues



- Make up filters
- Sea water recycle system
- Cranes
- Acid cleaning
- Control valves bypass

# Recent Ideas

Optimized thermodynamic  
and hydraulic design

Some issues



- Fouling factor
- Brine chamber load
- Release rate

# Into the future

We have seen how things were in the

**PAST**

and

We know how things are in the

**PRESENT**

but


How will things be in the

**FUTURE**

**?**

# Into the future

## Process

Fisia Italimpianti has presently in operation the largest MSF units in the world in Al Taweelah B (17.5 MIGD each), which superseded the previous record of Fisia's distillers in Shuweihat (16.7 MIGD each). 

**Ready for the jump to 20 MIGD Units**

**Some  
issues**




- TBT > 112 °C for extreme swt
- Optimal fouling factors
- Higher brine chamber loads

# Into the future

## Materials

Fisia Italimpianti R&D activities are continuously going on in search of new and better materials applications.

### Some issues



- Evaporator vessel
- Heat exchange tubes
- Demisters



# Conclusions

- **MSF technology has been applied for thermal desalination plants by today for more than 50 years.**
- **Though the basic principles of this way of making fresh water out from sea water remain the same, things have deeply changed.**
- **Fisia had the opportunity to design, build and commission all the MSF units installed in Jebel Ali from 1999 up to today.**
- **This overview on Fisia's work shows how...**

# Conclusions



... this "old" technology is today more than ever vital and on the way to even further improvements.